

[Proposed] Variance Conditions
Short Variance Case No. 6219-1
Hearing Date: January 6, 2022
The Newark Group, Inc., dba Greif, Inc. FID: 191386

1. Petitioner shall complete necessary repairs to Generator (Device D12), reinstall the unit and resume normal operation of the IC engine (Device D9) and Generator (Device D12) no later than February 28, 2022.
2. Petitioner shall successfully complete the following tests no later than March 31, 2022:
 - a. RECLAIM CEMS RATA
 - b. NH₃ (Ammonia) Source Test for IC engine (Device D9) and selective catalytic reduction (SCR) (Device C10).
3. Petitioner shall notify the South Coast AQMD that each of the following events has occurred. Such notification shall be provided by email to Hugh Heney, AQ Analysis and Compliance Supervisor, at Hheney@aqmd.gov no later than the deadlines set forth in Conditions 1 and 2 above.
 - a. Returning IC engine (Device D9) and Generator (Device D12) to operation.
 - b. Completing the RECLAIM CEMS RATA and NH₃ source tests.
4. Petitioner shall notify the Clerk of the Board in writing within five days of final compliance being achieved.
5. Petitioner shall pay all applicable fees to the Clerk of the Board on or before fifteen (15) days from the date the variance is granted or the variance shall be invalidated pursuant to Rule 303 - Hearing Board Fees, subsection (k).